
## SyCALL CDP - Installation Instructions





On the back of the call point there are 6 screw terminals connected to the internal PCB (3 wires for each internal switch). Every single switch contact is accessible indipendently. Connect wires as suggested in the table below.


Positive	Negative	Description
NC	С	Normally close switch (open circuit when activated
ON	С	Normally open switch (closed circuit when activated

## Reset Instructions


## **Dimensions**








Turn clockwise to reset





Material	Humidity	Operating Temperature	Cable Termination		Maximum current	Insulation resistance	Technical S <sub>I</sub>
ABS/Policarbonate/PA6+glass fiber	0 - 95 %	-30 / +70 °C	0,5 – 2,5 mm <sup>2</sup>	5A @ 125 VAC	3A @ 250 VAC	> 100 Mohm @ 500 VDC	Technical Specifications